



ALLOWABLE FOUNDATION TOLERANCES:

- WIDTH AND LENGTH $\pm 1/8"$ in 12'
- $\pm 1/4"$ OVERALL
- OUT OF SQUARE DIAGONALLY $\pm 1/2"$
- OUT OF LEVEL $\pm 1/8"$ in 20'
- $\pm 1/4"$ OVERALL

NOTE 1. ACTUAL FOUNDATION DESIGN MUST BE DONE BY AN ENGINEER FAMILIAR WITH LOCAL BUILDING CODES, SOIL CONDITIONS, ETC. IN THE AREA WHERE THE BUILDING IS TO BE CONSTRUCTED. THE TABULATION BELOW SHOWS THE NOMINAL LOADS INDUCED INTO THE PERIMETER FOUNDATION WALL.

NOTE 2. ANCHORS ARE DRILL IN PLACE WEDGE TYPE PROVIDED BY PARKLINE, INC.

FOUNDATION LOAD REQUIREMENTS

BLDG. WIDTH	VERTICAL LOAD: #/LIN.FT.				HORIZONTAL LOAD
	STANDARD DESIGN LOAD COMBINATIONS (LL/WL)				
	20/70	20/100	30/90	40/90	
5'-4" THRU 8'-0"	100	100	140	180	150# PER LINEAL FOOT
10'-8" AND 12'-0"	150	150	210	270	
16'-0" THRU 24'-0'	300	300	420	420	
28'-0" THRU 32'-0"	415	415	575	575	

THE VALUES SHOWN INCLUDE DEAD LOAD, LIVE LOAD AND WIND LOAD. ANY OTHER LOADS SUPPORTED BY THE BUILDING MUST BE ADDED AND THE FOUNDATION DESIGNED ACCORDINGLY.

MANUFACTURER

Parkline, Inc.
P.O. Box 65
Winfield, West Virginia 25213
(304) 586-2113 in WV
Phone: (800) 786-4855 outside WV
(304) 586-3842 FAX

Web : <http://www.parkline.com>
E-Mail : parkline@parkline.com



13122FDN